

Incorporated Village of Munsey Park

AIR CONDITIONING NOTES

1. All work shall be installed in accordance with the residential and mechanical codes of New York State, latest edition and the manufacturer's instructions.
2. All equipment shall be sized in accordance with ACCA manual S or other approved sizing methodologies based on building loads calculated in accordance with ACCA manual J.
3. Outdoor equipment shall be listed and labeled for outdoor installation. Supports and foundations shall prevent excessive vibration, settlement or movement of the equipment.
4. Equipment supported from the ground shall be level and firmly supported on a concrete slab or other approved material extending not less than 3 inches above the adjoining ground installed in accordance with the manufacturer's installation instructions.
5. Equipment suspended from the floor shall have a clearance of not less than 6 inches from the ground or as required by the manufacturer's installation instructions.
6. Equipment shall be installed with the clearances from unprotected combustible materials as indicated on the appliance label and in the manufacturer's installation instructions.
7. Attics containing appliances or equipment shall be provided with an openings and a clear and unobstructed passageway large enough to allow removal of the largest appliance or equipment, but not less than 30 inches high and 22 inches wide and not more than 20 feet long measured along the centerline of the passageway from the opening to the appliance. The passageway shall have continuous solid flooring in accordance with chapter 5 not less than 24 inches wide. A level service space not less than 30 inches deep and 30 inches wide shall be present along all sides of the appliance or equipment where access is required. The clear access opening dimensions shall be not less than 20 inches by 30 inches and large enough to allow removal of the largest appliance or equipment.
8. Wood-framed structural members shall be drilled, notched or altered in accordance with R502.8, R602.6, R602.6.1 and R802.7.
9. Where piping is installed through holes or notches in framing members and is located less than 1 1/2" from the framing member face to which wall, ceiling or floor membranes will be attached, the pipe shall be protected by shield plates that cover the width of the pipe and shall extend 2 inches to each side of the framing member.
10. The contractor/installer hereby certifies that the system will be installed in complete compliance with the residential and mechanical codes of New York State and all other applicable codes.

PRINT NAME

SIGNATURE

Sworn to before me this ____ day of _____, 2024

NOTARY PUBLIC